

LAB ON LOCALE™

Portable Gas Analysis System



Gass-og PusteService AS
www.gpsas.no

Customer	Tonsberg Dykkerklubb		
Test Date / Technician	06/27/17 11:12:29 AM / Joseph Ramirez		
Compressor Model	Lenhardt & Wagner 450ES		
Compressor Number	7/ 574		
Pressure	200 bar		
Test Standard	EN 12021:2014		
Analytes	Sample	Standard	Accuracy
Oxygen (%)	21.0	20 - 22	0.01%
Carbon Dioxide (ppm)	338.7	500	0.01%
Carbon Monoxide (ppm)	1.5	15	0.5%
Dew Point (°C)	-56.1	NA	0.5%
Oil & Particles (mg/m3)	Pass	0.5	NA
Water (H2O) 200 bar (mg/m3)	17.9	50	0.5%
Water (H2O) 300 bar (mg/m3)	N/A	30	0.5%
Odor	None	None	NA
Resultaten / Results	Sample Meets Standard		

Test performed by Lawrence Factor, Inc. for Gass-og PusteService AS - LOL000931

IMPORTANT: This air/gas or substance was tested only against a specified standard and may contain undetected items which are beyond the purpose or scope of this analysis. More extensive testing can be conducted upon request. This does not guarantee the condition nor safe application of the analyzed air/gas substance. Results reported relate only to the items tested. This report shall not be reproduced except in full, without the written consent of Lawrence Factor, Inc. Methods used: IR,

This report contains information which is confidential and may be legally privileged. The information is intended only for the individual or entity named on this report. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of this information is prohibited. If you received this report in error, please notify us by phone immediately so that we can arrange for retrieval of the original report.



Technician / Joseph Ramirez

Endorsement / President

X-zam Laboratories